

FROM: ANTINOZZI ASSOCIATES
271 FAIRFIELD AVENUE
BRIDGEPORT, CT 06604

TO: ALL BIDDERS

RE: JOB NO. 24034
TOWN OF MONROE
ST. JUDE SCHOOL
GYMNASIUM WALL REPAIR
707 MONROE TPK., MONROE, CT

SUBJECT: ADDENDUM NO. 3

DATE: APRIL 17, 2025

This Addendum shall be part of the Contract Documents for the referenced Bid. The Addendum is to acknowledge by the bidder on the Bid Form.

The following ADDENDUM is issued to clarify items appearing either in the specifications or on the Drawings, said items having been called to the attention of the Architect by one or more of the Contractors estimating the work:

The Specifications and / or drawings are amended as follows:

1. CLARIFICATIONS & REVISIONS

- A. Delete Note K on the INFO-1 Drawing as there are no electrical drawings for this project. The electrical work is limited to the installation of a new exterior light fixture as shown on the South Elevation on Drawing A-301 and any electrical devices, outlets, switches, etc. that need to be removed from the gym walls and replaced in kind with the completion of the new walls. In general, any mechanical and electrical work required to complete the removal and replacement of the gym walls and associated work is the responsibility of the General Contractor.

END OF ADDENDUM NO. 3